



4705



UKCA CERTIFICATE

APPROVED BODY NUMBER 0843

UK CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 0843-CPR-1224

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer: Polyseam Ltd

Address: 15 St. Andrews Road, Huddersfield, West Yorkshire, HD1 6SB, UK

Product Description: Firestop – Penetration Seals and Linear Joint Seals

Model Reference: Protecta FR IPT


Places of production: Polyseam Ltd, 15. St. Andrews Road, Huddersfield, West Yorkshire HD1 6SB, UK

UK Assessment Document(s) & UKTA: 0843-UKTA-22/0028 & 0843-UKTA-22/0029 and EAD 350454-00-1104 & EAD 350141-00-1106

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in 0843-UKTA-22/0028 & 0843-UKTA-22/0029 and EAD 350454-00-1104 & EAD 350141-00-1106 under system 1/1+ for the performance set out in the UKTA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 29th November 2022 and will remain valid as long as neither the UKTA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of 1st issue: 29th November 2022
Issue: 1
Date of re-issue: N/A
Issued by UL International (UK) Ltd., Approved Body 0843.

Signed: 
Name: Chris Johnson
Certification Decision Maker

Page 1 of 2



4705



UKCA CERTIFICATE

Schedule for certificate No. 0843-CPR-1224

Detailed information sheet

Model Reference: Protecta FR IPT
Type: Firestop – Sealant used as a penetration seal and linear joint seal
Description: A sealant used to form a penetration seal around cables, conduits, metallic pipes and plastic pipes to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. The sealant can also be used to form linear gap seals where gaps are present in floor to floor/floor to wall and in walls. Typical locations of linear joints include floors, the perimeter of floors, walls, ceilings and roofs. The Protecta FR IPT is supplied in liquid form contained within 200 ml, 300 ml, 380 mm and 600 ml containers. The sealant is gunned into the aperture in the separating element/elements and around the service or services, to a specified depth utilising a backing material.
Key Performance parameters: See 0843-UKTA-22/0028 & 0843-UKTA-22/0029

Limitations on the acceptance or use of the product(s):


Installation instructions To be used in accordance with the supplier's installation instructions.

Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

Date of 1st issue: 29th November 2022
Issue: 1
Date of re-issue: N/A
Issued by UL International (UK) Ltd., Approved Body 0843.

Signed: 
Name: Chris Johnson
Certification Decision Maker

Page 2 of 2