



4705



# UKCA CERTIFICATE

## APPROVED BODY NUMBER 0843

### UK CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 0843-CPR-1184

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer: Polyseam Ltd

Address: 15 St. Andrews Road, Huddersfield, West Yorkshire, HD1 6SB, UK

Product Description: Firestop – Linear Joint and Gap Seal

Model Reference: Protecta FR Coating


Places of production: Polyseam Ltd, 15. St. Andrews Road, Huddersfield, West Yorkshire HD1 6SB, UK

UK Assessment Document(s) & UKTA: 0843-UKTA-22/0021 and EAD 350141-00-1106

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in 0843-UKTA-22/0021 and EAD 350141-00-1106 under system 1/1+ for the performance set out in the UKTA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 27<sup>th</sup> September 2022 and will remain valid as long as neither the UKTA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of 1<sup>st</sup> issue: 27<sup>th</sup> September 2022  
Issue: 1  
Date of re-issue: N/A  
Issued by UL International (UK) Ltd., Approved Body 0843.

Signed:   
Name: Chris Johnson  
Certification Decision Maker



4705



# UKCA CERTIFICATE

## Schedule for certificate No. 0843-CPR-1184

### Detailed information sheet

Model Reference: Protecta FR Coating  
Type: Firestop – Coating for stone, mineral wool board used as a linear joint seal  
Description: Protecta FR Coating is an ablative sealant coating designed to enhance, seal and fire protect mineral fibres. Protecta FR Coating is a sprayed coating product that is site or factory applied to both faces of a stone wool, mineral fibre board or site applied to one face of stone wool mineral fibre backer, to form a linear joint seal system. The intended use of Protecta FR Coating is to reinstate the fire resistance performance of floor to floor/ floor to wall joints and wall gaps. Typical locations of linear joints include floors, the perimeter of floors, walls, ceilings and roofs.  
Key Performance parameters: See 0843-UKTA-22/0021

### Limitations on the acceptance or use of the product(s):


Installation instructions To be used in accordance with the supplier's installation instructions.

### Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

Date of 1<sup>st</sup> issue: 27<sup>th</sup> September 2022  
Issue: 1  
Date of re-issue: N/A  
Issued by UL International (UK) Ltd., Approved Body 0843.

Signed:   
Name: Chris Johnson  
Certification Decision Maker

Page 2 of 2